

Certificate of Compliance

This certificate is issued for the following:

Polyethylene (PE) Pipe and Fittings for Underground Fire Protection Service (see detail on following pages)

Prepared for:

AGRU-FRANK GmbH Dieselstrasse 1-7 Wolfersheim-Berstadt, 61200 Germany

Manufactured at:

AGRU-FRANK GmbH Dieselstrasse 1-7 Wolfersheim-Berstadt, 61200 Germany

FM Approvals Class: 1613

Approval Identification: 0003058569 Approv

Approval Granted: June 28, 2017 Report Reissued: August 3, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David Fuller

VP - Manager of Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Product Designation	O.D., Pipe Size, mm	Pressure Rating, bar (psi)	Remarks
Pipe, PE 100, SDR 11 Extruded	63, 75, 90,110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	15 (218)	a, b, c
Pipe, PE 100, SDR 9 Extruded	63, 75, 90,110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	17.5 (250)	a, b, c
Sweep Bend Fittings, 90°, 60°, 45°, 30°, 22°, 11°, Extruded and Formed SDR 11	90, 110, 125, 140, 160, 180, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	15 (218)	a, b, c
Sweep Bend Fittings, 90°, 60°, 45°, 30°, 22°, 11°, Extruded and Formed SDR 9	90, 110, 125, 140, 160, 180, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	17.5 (250)	a, b, c

Remarks:

- a. Dimensions refer to the pipe outside diameter. Pipe and fittings are directly connected by the butt fusion process, or the socket electro-fusion welding process.
- b. The manufacturer fusion welding instructions must be strictly adhered to for a proper joint.
- c. The color of the pipe is Black or Blue



Member of the FM Global Group