

DESC: 18/2 PLTC 105C 300V

DATE: 12/01/09

SCALE: 25x

NORTHWIRE

M SPECS.

DWG NO: FPLTC182-006

DR. BY: D. OLSON NWI NO: SEE BELOW

A. 18 AWG 16X30 BC STRANDING O.D. .049±.003"

B. 15 MILS PVC INSULATION 13 MILS PVC MIN. INSULATION 0.D. .079±.002"

C. TISSUE PAPER SEPARATOR

D. 35 MILS PRESSURED PVC JACKET 28 MILS MIN. PVC JACKET

JACKET COLOR: GRAY

CABLE IS UL AND CSA APPROVED CABLE IS RoHS COMPLIANT

ELECTRICAL REQUIREMENTS: DIELECTRIC WITHSTAND VOLTAGE 1.5 KVAC

MECHANICAL REQUIREMENTS:

NONE SPECIFIED

DO NOT BUILD IN NEW MEXICO. CUSTOMER CAN'T USE THE PRODUCT WITH THE NEW MEXICO LEGEND.

NWI P/N			CUSTOMER P/N		
BPLTC182-001	-	BULK CABLE			
FPLTC182-007	_	100' COIL	400299-1200		
FPLTC182-006W	_	1,000' PUT-UPS	400299		

BLACK INK PRINT WISCONSIN LEGEND 18 AWG/2 (UL) PLTC 105C E90625 SUNLIGHT RESISTANT WET LOCATION OR CSA CMX-OUTDOOR-CMG LL54185 105C FT4

Added NWI bulk and 100' coil part numbers.	C	04/12/10	DO	
Removed New Mexico part number and legend from drawing.	В	12/28/09	DO	
INITIAL RELEASE	Α	12/01/09	DO	
REVISION RECORD	REV	REV DATE	APPROVAL	APPROVAL